

PRODUCT FICHE

LOGIC SYSTEM S IE BOILER

Ideal Boilers

ERP DATA

| | SYMBOL | UNITS | MODEL | | | |
|--|----------|-------|-------|-----|-----|-----|
| | | | 15 | 18 | 24 | 30 |
| Condensing boiler | | | Yes | | | |
| Seasonal Space heating efficiency class | | | A | | | |
| Rated heat output | | kW | 15 | 18 | 24 | 30 |
| Seasonal space heating energy efficiency | η_s | % | 93* | 93* | 94* | 93* |
| Annual energy consumption | Q_{HE} | GJ | 47 | 56 | 75 | 93 |
| Sound power level, indoors | L_{WA} | dB | 44 | 46 | 48 | 48 |

Seasonal Space Heating Energy Efficiency of the Boiler

*%

A

Temperature control (from fiche of temperature control)

%

B

| Class I | Class II | Class III | Class IV | Class V | Class VI | Class VII | Class VIII |
|---------|----------|-----------|----------|---------|----------|-----------|------------|
| 1% | 2% | 1.5% | 2% | 3% | 4% | 3.5% | 5% |

Solar Contribution (from fiche of solar device)

Collector Size
(in m²)

Tank Volume
(in m³)

Collector
Efficiency
(in %)

Tank rating
A* = 0.95
A = 0.91
B = 0.86
C = 0.83
D-G = 0.81

$$= ('III' \times \boxed{} + 'IV' \times \boxed{}) \times 0.9 \times (\boxed{} / 100 \times \boxed{} =$$

%

C

Seasonal Space Heating Energy Efficiency of Package

TOTAL: A+B+C=

%

Seasonal Space Heating Energy Efficiency Class of Package

| | | | | | | | | | |
|-------|-------|-------|-------|-------|-------|-------|-------|--------|--------|
| | | | | | | | | | |
| < 30% | ≥ 30% | ≥ 34% | ≥ 36% | ≥ 75% | ≥ 82% | ≥ 90% | ≥ 98% | ≥ 125% | ≥ 150% |

The energy efficiency of the package of products provided for in this document may not correspond to its actual energy efficiency once installed in a building, as the efficiency is influenced by further factors such as heat loss in the products in relation to the building size and its characteristics